

Area of measurement for item "Handicap Ramp w/Truncated Domes"

4'x4' Landing
Recommended slope 1.5%, maximum slope 2.0% any direction
(must drain to street)

Side of ramp may have a returned curb or flare with no maximum flare slope (returned curbs will be measured in sq ft and paid at ramp rate)

Minimum Running Slope 5%, Maximum 8%

Minimum 4' flat area

Truncated domes, minimum 2' x 4' (must be all the way across flat area)

Maximum cross slope 2.0%, or not to exceed cross slope of street

Truncated domes to be placed against back of curb

18" Max. Flare

18" Max. Flare

No Lip

Match slope of flare

Maximum counter slope 5.0% for 2'

Gutter may need to be adjusted to prevent exceeding maximum counter slope. **Proper drainage must be maintained.**

4'x4' Street Landing

Street Landing must fall completely within any marked crosswalk



Type I (Perpendicular) Curb Ramp

300-16
Revised 1/2008