



NOTE:
ALL TYPES MAY BE PLACED WITH OR WITHOUT A 6 INCH BED OF NO. 3 OR 4 CRUSHED GRAVEL, STONE, OR SLAG AS SPECIFIED BY THE ENGINEER.

NOTE:
DEPTH "D", MEASURED PERPENDICULAR TO SLOPE, SHALL BE AS SPECIFIED BY THE ENGINEER.

TYPE "A" SHALL CONSIST OF SIZES SUCH THAT AT LEAST 85 PERCENT OF THE TOTAL MATERIAL BY WEIGHT SHALL BE LARGER THAN AN 18-INCH SQUARE OPENING. THE MATERIAL SMALLER THAN AN 18-INCH SQUARE OPENING SHALL CONSIST PREDOMINANTLY OF ROCK SPALLS AND ROCK FINES AND SHALL BE FREE OF SOIL.

TYPE "B" SHALL CONSIST OF SIZES SUCH THAT AT LEAST 85 PERCENT OF THE TOTAL MATERIAL BY WEIGHT SHALL BE LARGER THAN A 9-INCH SQUARE OPENING. THE MATERIAL SMALLER THAN A 9-INCH SQUARE OPENING SHALL CONSIST PREDOMINANTLY OF ROCK SPALLS AND ROCK FINES AND SHALL BE FREE OF SOIL.

TYPE "C" SHALL CONSIST OF SIZES SUCH THAT AT LEAST 50 PERCENT OF THE TOTAL MATERIAL BY WEIGHT SHALL BE LARGER THAN A 9-INCH SQUARE OPENING, AND SHALL BE FREE OF SOIL. THE AMOUNT OF MATERIAL PASSING A 3 INCH SIEVE SHALL BE NOT MORE THAN 15 PERCENT BY WEIGHT OF THE TOTAL MATERIAL.

ROCK CHANNEL PROTECTION