



# Irrigation Meters

Are there additional requirements for an irrigation system or pool?

For most applications, a dual check (ASSE 1024) backflow prevention device is allowed. However, if the meter services an irrigation system or a pool, then a testable vacuum breaker (ASSE 1020) or reduced pressure zone device (ASSE 1013) is required. A certified backflow tester must test the device when it is installed and every twelve months thereafter.

To see larger drawings visit:  
[www.ci.fairborn.oh.us/  
standard\\_drawings.htm](http://www.ci.fairborn.oh.us/standard_drawings.htm)

All drawings are listed by number.

#800-3 Water Main & Inside  
Service Connections  
#800-7 Water Meter Installation

Call the Water & Seer Division at  
754-3097 for further information  
about irrigation meters.

# Using & Installing Irrigation Meters

City of Fairborn  
44 W. Hebble Avenue  
Fairborn, OH 45324

937-754-3030

[www.ci.fairborn.oh.us](http://www.ci.fairborn.oh.us)



City of Fairborn  
44 W. Hebble Avenue

937-754-3097

[www.ci.fairborn.oh.us](http://www.ci.fairborn.oh.us)